

## Réunions scientifiques

Séminaire SOLEIL

## X-ray Detector Development at Berkeley Lab.

## **Peter DENES**

(Advanced Light Source, Lawrence Berkeley National Lab, Berkeley, USA)

Invité par Stéphanie HUSTACHE et la section MMI

## Lundi 5 décembre à 14h00 Grand Amphi SOLEIL

"Moore's Law" predicts<sup>1</sup> a doubling of the number of transistors per unit area roughly every 2 years. Synchrotron radiation light sources have done twice as well: doubling their performance measure – *brightness* – roughly every year. That means that our ability to *use* photons is falling exponentially behind our ability to *make* them.

Berkeley Lab has been building microelectronic-enabled detectors for more than 20 years, with particular interests in silicon strips, pixels and Charge-Coupled Devices (CCDs). At the Microsystems Laboratory, we have developed thick, fully-depleted CCDs<sup>1</sup>, which have near unity efficiency for X-rays up to 8 keV. Together with a suite of custom integrated circuits, this has allowed us to provide novel high-speed 2D detectors for photon and electron microscopies.

We have developed fast (hundreds of megapixel frames/second) direct detection X-ray CCD cameras, and in collaboration with the Advanced Photon Source (APS) have deployed several prototype systems $^1$ . These initial systems have been used for soft X-ray ptychography, photon correlation spectroscopy and microdiffraction at ALS and APS, as well as soft X-ray scattering at LCLS $^1$ . Larger, more sophisticated systems are currently being built, and will be described. R&D is also under way on ultra-thin backside contacts in order to maximize low energy X-ray quantum efficiency, as well as a next generation of high-speed direct-detection CCD, designed for  $10^3-10^4$  frames/second.

As ALS is primarily a soft X-ray facility, our focus is on the challenges of soft X-ray detectors. CMOS active pixels, grown on thick high-resistivity silicon, offer attractive prospects for new X-ray detectors, and we are just deploying a 4,000 frame/second gated detector for use at ALS femtoslicing beamline. For soft X-rays, thinned bulk CMOS active pixels, with backside contacts, together with advances in data compression and processing, offer a potential approach to reach rates of 10<sup>5</sup> frames/second. All of the techniques mentioned above are applicable for photoelectron detection as well.

D. Doering, Y.-D. Chuang, N. Andresen, K. Chow, D. Contarato, C. Cummings, E. Domning, J. Joseph, J.S. Pepper, B. Smith, G. Zizka, C. Ford, W.S. Lee, M. Weaver, L. Patthey, J. Weizeorick, Z. Hussain, and P. Denes, Development of a Compact Fast CCD Camera and Resonant Soft X-ray Scattering Endstation for time-resolved Pump-Probe experiments, Rev. Sci. Inst., in press.



Formalités d'entrée : accès libre dans l'amphi du Pavillon d'Accueil. Si la manifestation a lieu dans le Grand Amphi Soleil du Bâtiment Central, merci de vous munir d'une pièce d'identité (à échanger à l'accueil contre un badge d'accès).

SYNCHROTRON SOLEIL

Division Expériences - L'Orme des merisiers - Saint-Aubin - BP 48 – 91192 GIF S/YVETTE Cedex http://www.synchrotron-soleil.fr/portal/page/portal/Soleil/ToutesActualites
Secrétariat Division Expériences : <a href="mailto:sandrine.vasseur@synchrotron-soleil.fr">sandrine.vasseur@synchrotron-soleil.fr</a>

<sup>&</sup>lt;sup>1</sup> G.E. Moore, Cramming more components onto integrated circuits, Electronics, **38** (1965)

S. E. Holland, D. E. Groom, N. P. Palaio, R. J. Stover, and M. Wei, IEEE Trans. Elect. Devices, 50, 225-238 (2003)

<sup>&</sup>lt;sup>1</sup> P. Denes, D. Doering, H. A. Padmore, J.-P. Walder, and J. Weizeorick, *A fast, direct X-ray detection charge-coupled device*, Rev. Sci. Inst, **80**, 083302 (2009)